



September 27, 2019

CITY OF RANCHO MIRAGE ADDENDUM NO. 5

**TRAFFIC SIGNAL INTERCONNECT IMPROVEMENTS
PROJECT NOS. C.P. 13-308-014 & CP 13-308-015**

TO ALL PROSPECTIVE BIDDERS:

GENERAL INSTRUCTIONS:

This Addendum No. 5 ("Addendum No. 5") is being issued subsequent to and as part of the issuance of the City of Rancho Mirage Notice Inviting Sealed Bids for Traffic Signal Interconnect Improvements, Project Nos. C.P. 13-308-014 and CP 13-308-015, dated August 7, 2019, and the associated Bid Packet containing Contract Documents and Specifications (collectively, "Bid Packet"). This Addendum No. 5 constitutes an integral part of the Bid Packet, Addendum to Bid Packet issued by the City of Rancho Mirage ("City") September 5, 2019 ("Addendum No. 1"), Addendum No. 2 to the Bid Packet, issued by the City on September 9, 2019 ("Addendum No. 2"), Addendum No. 3 to the Bid Packet, issued by the City on September 12, 2019 and Addendum No. 4 to the Bid Packet, issued by the City on September 20, 2019. Where inconsistent with the Bid Packet, Addendum No. 1, Addendum No. 2, Addendum No. 3 and Addendum No. 4, this Addendum No. 5 shall govern. It is the responsibility of all respondents to the Bid Packet, Addendum No. 1, Addendum No. 2, Addendum No. 3 and Addendum No. 4 to conform to this Addendum No. 5. Unless specifically changed herein, all other requirements, terms and conditions of the Bid Packet, Addendum No. 1, Addendum No. 2, Addendum No. 3 and Addendum No. 4 remain unchanged. All terms capitalized herein shall have the same meaning ascribed to them in the Bid Packet.

The following changes, corrections, and clarifications shall be made a part of the plans, specifications, and contract documents on this project:

The NOTICE INVITING SEALED BIDS, on page 00100-1 of the Bid Packet, is hereby revised to add a **COMMENTS AND QUESTIONS DEADLINE** to the first paragraph. Such first paragraph shall read as follows:

PUBLIC NOTICE IS HEREBY GIVEN that the City of Rancho Mirage, hereinafter referred to as CITY, invites sealed bids for the above-stated project and will receive such bids in the offices of the City Engineer up to the hour of **2:00 P.M., on WEDNESDAY, October 2, 2019**, at which time they will be publicly opened and read aloud. **WRITTEN COMMENTS AND QUESTIONS SHALL BE SUBMITTED BY NO LATER THAN 2:00 P.M. ON FRIDAY, SEPTEMBER 27, 2019.**

Additionally, several questions have been asked by plan holders. The questions with the corresponding answers by the City are listed below.

Question 1: Bid proposal sheet – revised bid schedule 14 (addendum 1) and revised bid schedule 15 (addendum1) **bid item 4** calls for New Advanced Transportation controller (ATC). However, construction note #3 on all intersection project plans specify Controller, MMU and BIU.

3 REMOVE AND SALVAGE EXISTING ECONOLITE CONTROLLER TO CITY YARD. FURNISH AND INSTALL ECONOLITE COBALT ATC CONTROLLER OR APPROVED EQUAL. FURNISH AND INSTALL NEW COMPATIBLE ECONOLITE MALFUNCTION MANAGEMENT UNITS (MMU) WITH ETHERNET PORT AND BUS INTERFACE UNITS (BIU) OR APPROVED EQUALS.

Please confirm that this note refers ONLY to intersections that DO NOT REQUIRE A NEW CABINET as shown in the table below (as all locations with new cabinets will included with an MMU and BIU).

Answer: Yes, note only refers to intersections and does not require a new cabinet.

Question 2: Please also advise if a quantity of 14 MMU's and BIU's for the locations shown in the table below should be included in Bid schedule line item 4 for the New Advanced Transportation controller (ATC) –

OR

amend the bid schedule to reflect a BIU or MMU separately.

Intersection #	Page #	Intersection Name
1	4	Highway 111 @ One Mirage Pl
2	5	Highway 111 @ Frank Sinatra
13	16	Highway 111 @ Button Dr.
20	24	Bob Hope @ Country Club Dr.
24	25	bob hope @ Frank Sinatra Dr.
28	27	Monterey Ave @ Ave Las Palmas / Gran Via
29	27	Monterey Ave @ Clancy Ln
30	28	Monterey Ave @ Hovley Ln
32	28	Monterey Ave @ Country Club

33	28	Monterey Ave @ Shadow Ridge Rd.
36	29	Monterey Ave @ Dick Kelly Dr.
38	31	Dinah Shore Dr @ Miriam Way
39	31	Dinah Shore Dr @ Shoppers Lane
40	32	Dinah Shore Dr @ Monterey Ave.

Answer: Yes, please include Bid Schedule line item 4 for the New Advanced Transportation Controller (ATC).

Question 3: For the three spare controllers being requested, is a MMU and BIU to also be provided per construction note# 3?

Answer: Yes.

Question 4: Regarding Cabinets:

- The bid schedule calls for 28, plan sheets indicate 26 new cabinets. Please update bid schedule accordingly.

Answer: Revised Bid Schedule calls for 23 cabinets in Schedule 14 and 4 cabinets in Schedule 15. 27 total.

*****END ADDENDUM NO. 5*****

All other project plans and specifications stay the same.

ALL BIDDERS SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM NO. 5 AND ITS ATTACHMENTS BY SIGNING THE ATTACHED RECEIPT SHEET AND SUBMITTING THE SIGNED SHEET WITH THEIR BID PROPOSAL. FAILURE TO COMPLY MAY BE CAUSE TO CONSIDER THE BID NON-RESPONSIVE.

Sincerely,



for William A. Enos
City Engineer

ADDENDUM RECEIPT SHEET

ADDENDUM NO. 5

**TO: CITY OF RANCHO MIRAGE
CITY ENGINEER**

RE: CITY PROJECT NOS. 13-308-014 and 13-308-015

By signing this form, I hereby acknowledge receipt of Addendum No. 5 dated September 27, 2019 ("Addendum No. 5") to the City of Rancho Mirage Notice Inviting Sealed Bids for Traffic Signal Interconnect Improvements, Project Nos. C.P. 13-308-014 and CP 13-308-015, dated August 7, 2019, and the associated Bid Packet containing Contract Documents and Specifications (collectively, "Bid Packet"). I covenant and agree to include this signed instrument as part of any proposal package submitted in response to the Bid Packet, Addendum No. 1, Addendum No. 2, Addendum No. 3, Addendum No. 4 and Addendum No. 5.

Receipt of Addendum No. 5 and its attachments is hereby acknowledged.

Bidder

Signature

Date

**THIS PAGE TO BE ATTACHED TO YOUR BID.
FAILURE TO ATTACH THIS PAGE TO YOUR BID MAY BE
CAUSE TO CONSIDER YOUR BID NON-RESPONSIVE.**